



Certificate of Compliance

Certificate: 2521843

Master Contract: 252270

Project: 2521843

Date Issued: June 27, 2013

Issued to: American Products
597 Evergreen Road
Strafford, MO 65757
US
Attention: David A. Buescher

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Wardell Dumas

Issued by: Wardell Dumas

PRODUCTS

- CLASS 3211 11** - INDUSTRIAL CONTROL EQUIPMENT - Enclosures for Electrical Equipment
CLASS 3211 91 - INDUSTRIAL CONTROL EQUIPMENT - Enclosures for Electrical Equipment US Requirements

AMxxP-26yy-zzRU ('xx' may either be 32, 47, 58, 68 or 78 indicating the overall height of enclosure in inches notwithstanding optional accessories; 'yy' may either be 25, 30 or 36 indicating the overall depth of enclosure notwithstanding optional accessories. 'zz' corresponds with the height of the enclosure and indicates the cabinet rack unit (RU) capacity: 16, 24, 30, 36, or 42.)

Notes:

These enclosures are intended for electrical equipment use as industrial control where the complete assembly is approved for installation in non-hazardous locations in accordance with the National Electrical Code (NEC), Canadian Electrical Code (CEC) or the like in accordance with local authorities having jurisdiction.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 94.1-07 / UL 50 12 Ed. (Harmonized) Enclosures for Electrical Equipment, Non-Environmental Considerations



Certificate: 2521843

Master Contract: 252270

Project: 2521843

Date Issued: June 27, 2013

CSA C22.2 No. 94.2-07/ UL 50E 1st Ed. (Harmonized) Enclosures for Electrical Equipment, Environmental Considerations